



- NOTES:
1. Depth of sanitary sewer and storm drain per City Engineer.
 2. Depth of under drain shall be 3'-6" from gutter line to pipe invert.
 3. Depths of electric, telephone, cable television and fire to be at least 36 inches below finish grade. Depths of other utilities per requirements of applicable utility company.
 4. Applicable warning tape shall be placed over each utility.
 5. Rigid PVC conduit is required for street and driveway crossings and other pavement crossings more than 12 feet in length. Conduits crossing streets shall be encased in concrete.

STREET CLASSIFICATION	R.O.W. WIDTH (ft.)	UTILITY LOCATION DIMENSIONS	
		W (ft.)	G (ft.)
MINOR RESIDENTIAL	50	5	5
COLLECTOR RESIDENTIAL	50	5	5
COLLECTOR	60	7	7
ARTERIAL & COMMERCIAL	66	8	8

TYPICAL UTILITY LOCATIONS IN STREETS

NOT TO SCALE

FIGURE I-5 TYPICAL UTILITY LOCATIONS IN STREETS